

David P. Ainsworth, P.E.
1200 NW Hearn Ave, Blue Springs, MO 64015
Cell Phone: 816-682-2093
Email: dainsworth@chelepis.com

January 10, 2022

Mr. Mark Yancik
508 NW Manor Drive
Blue Springs, MO 64014


Re: Property @
4816 NE Jamestown Dr
Lee's Summit, MO.
Monticello Lot 124
Trumark Permit 2021-3683

Dear Mr. Yancik:

I have inspected the above referenced property to address issues raised by the Building Inspector.

In the area of the Master Closet and Bath metal strapping has been added from the rafters down to the stud walls. This is adequate to resist any upload on the roof.

Cordially,



David P. Ainsworth, P.E.

