

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210049
Address: 3018 NW THOREAU PL, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|---------------|----------|--------------------------|
| Occupancy Inspection - Codes Residential | Shawn Hoffman | Failed | Monday, January 10, 2022 |

Corrective Action Required:

| | | |
|---|--------------------------|--|
| 1 | Miscellaneous Correction | -Loft windows larger than 9 sq. ft and located less than 18" above floor are required to be tempered glass |
|---|--------------------------|--|

Corrective Action Required:

| | | |
|---|------|--|
| 2 | Misc | <ul style="list-style-type: none">- Complete final grading and sod- Obtain splash blocks- lightning fixture with in 8' on tub edge- Lock and secondary lock for sliding door to deck- 2@ 1/2" through bolts on each post to beam connections |
|---|------|--|

Comments: