

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20214329  
Address: 940 NW PRYOR RD, Unit:J, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                                    | Inspector:      | Outcome: | Date:                    |
|--|-----------------|----------|--------------------------|
| <b>Occupancy Inspection - Codes Commercial</b> | Michael Harkins | Failed   | Monday, January 10, 2022 |

Corrective Action Required:

|   |                          |   |
|---|--------------------------|---|
| 1 | Miscellaneous Correction | Label service panel breakers<br>Insulate sink plumbing in restroom<br>Install drinking fountain per plans<br>Install water heater per plans |
|---|--------------------------|---|

**Comments:**