

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20213473  
Address: 310 SW BLUE PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Michael Harkins	Failed	Monday, January 10, 2022

Corrective Action Required:

1	Miscellaneous Correction	INSULATE PLUMBING RESTROOM SINKS PROVIDE TEMPORARY BARRICADE BETWEEN CONSTRUCTION / RETAIL SPACE PROVIDE CORRECT ADDRESS REAR DOOR THE MEANS OF EGRESS SHALL BE ILLUMINATED IN ACCORDENCE WITH SECTION 1008.1 2018 IBC
---	--------------------------	--

**Comments:**