

David P. Ainsworth, P.E.
1200 NW Hearn Ave, Blue Springs, MO 64015
Cell Phone: 816-682-2093
Email: dainsworth@chelepis.com

January 10, 2022

Mr. Mark Yancik
508 NW Manor Drive
Blue Springs, MO 64014

Re: Property @
1241 NE Goshen Dr
Lee's Summit, MO.
Monticello Lot 69
Trumark Permit 2021-3689

Dear Mr. Yancik:

I have inspected the above referenced property to address concerns raised by the Building Inspector.

1. Garage PFH wall lvl header not going from corner to corner.

The lvl header is adequately supported by load bearing wall at both ends.

2. Over notched 2x10 rafters at exterior wall bearing

Metal strapping has been installed from the rafters to the stud wall and is adequate to resist upload on the roof.

Cordially,



David P. Ainsworth, P.E.

