

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211034
Address: 318 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Ronald Paynter	Passed	Tuesday, January 11, 2022

Informational:	
1 Misc	Driveway was framed and had 4" of aggregate in and compacted. Meets LS and ADA spec. 11/3 ES

Corrective Action Required:	
2 Misc	Driveway approach is out of tolerance through the 5' sidewalk lane and doesn't meet LS/ADA spec. Need to remove and replace. 11/12 ES

Informational:	
3 Misc	Finished driveway meets LS and ADA specs. RP 1-11-22

Comments: