

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212434
Address: 1837 SW SAGE CANYON RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Robb Popp	Failed	Tuesday, January 11, 2022

Informational:

1	Miscellaneous Correction	-PORTAL FRAME INSPECTION 8-15-21 **OK TO COVER EXTERIOR ONLY
---	--------------------------	---

Corrective Action Required:

2	Misc	-furr down ceiling to allow for insulation at HVAC at garage -fireblock HVAC/plumbing chase at great room -address overbored stud for DWV 1st floor bedroom hall -seal penetrations in air return for water heater pex at basement -3 1/2" SCH 40 steel columns at basement beam pier locations "D" and "C" per plans, 3" installed -Nail joist hangers in dining
---	------	--

Comments: