

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215542
Address: 1805 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Residential	Patrick Schonfeldt	Failed	Tuesday, January 11, 2022

Corrective Action Required:

1	Misc	1/11/22 - PARTIAL INSPECTION OF UNDERGROUND GAS LINE FROM STUB UP AT METER TO STUB UP AT POOL HEATER, INSPECTION AND PRESSURE TEST OF COMPLETED GAS LINE REQUIRED, OK TO COVER UNDERGROUND PIPING
---	------	---

Comments: