



# City Comment Response

1617 Walnut St., Kansas City, MO 64108  
816.581.6363

**Project:** Smoothie King  
1440 NE Douglas St,  
Lee's Summit, MO 64086

#PRCOM202200067

**Original Issue Date:** 01/04/22

**Date:** 01/10/22

**Architect's  
Project No:** 2021-099

**Project  
Manager:** MMP

---

The documents for the above referenced project are hereby revised according to the following and the attached.

**Comments:**

- Project is being bid and subcontractor information will be provided by General Contractor once selected prior to picking up permit.

---

**Attachments:**

Updated full drawing set. Added sheet A-1a for UL Assemblies and revised sheets A-0,A-3, A-6.

---

**Specifications:**

No changes were made to the specifications.

---

**Drawings:**

- **A-0**
  - Added sheet A-1a to provide complete UL Assembly.
- **A-1a**
  - Added complete UL detail for fire rated assembly UL U425.
- **A-3**
  - Added vertical grab bar to views 1,2&3/A-3.
  - Wall finish for rear wall and wall adjacent to water closet is identified in details 2/A-3 and 3/A-3.
  - Added vertical grab bar to Toilet Accessories schedule.
- **A-6**
  - Wall finish for rear wall and wall adjacent to water closet is identified in 1/A-6.

---

**cc:** ☐ : file  
☐ :