

### **PLANS REVIEW CONDITIONS**

Permit No:	PRCOM20215409	Date:	January 11, 2022
Project Title:	TWISTED FRESH	Applicant:	
Location:			
940 NW PRYOR RD, Unit:A, LEES SUMMIT, MO 64081		BAMFORD FIRE SPRINKLER CO INC	
Type of Work:		5134 MERRIAM DR	
Occupancy Group:	A-2	SHAWNEE MISSION, KS 66203	
Description:	TENANT FINISH FOR NEW	Primary: (913) 432-6688	
RESTAURANT			
Construction Type:	Type VA (1 hour)		
Map Page:			

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

#### **Sprinkler Plan Review**

**Reviewed By: Jim Eden**

**Released for Construction**

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

A visual inspection will be completed at the alarm test.

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**