



PLANS REVIEW CONDITIONS

Permit No:	PRCOM20213199	Date:	January 11, 2022
Project Title:	COMFORT DENTAL	Applicant:	
Location:	1153 NE RICE RD, LEES SUMMIT, MO 64086		
Type of Work:			ATRONIC ALARMS INC
Occupancy Group:	B		8220 MELROSE DR
Description:	TENANT FINISH FOR DENTAL CLINIC		LENEXA, KS 66214
Construction Type:	Type VB (Unprotected)	Primary:	(913) 362-0000
Map Page:			

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Jim Eden

Released for Construction

1. 2018 IFC 904.4.2- Alarm testing. Notification appliances, connections to fire alarm systems, and connections to approved supervising stations shall be tested in accordance with this section and Section 907 to verify proper operation.

Call (816) 969-1300 to schedule a test.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.