

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20212434  
Address: 1837 SW SAGE CANYON RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Shawn Hoffman	Failed	Wednesday, January 12, 2022

Informational:

1	Miscellaneous Correction	-PORTAL FRAME INSPECTION 8-15-21 **OK TO COVER EXTERIOR ONLY
---	--------------------------	---

Corrective Action Required:

2	Misc	-address overbored stud for DWV 1st floor bedroom hall -Nail joist hangers in dining
---	------	---

**Comments:**