

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20214193
Address: 501 NE WENONGA PL, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Partial	Wednesday, January 12, 2022

Corrective Action Required:

1	Misc	-Bath fan flexible ducts cannot exceed 14 ft. Need to start switching to 4" flexible or hard duct per IRC1505 **Bathroom fan in basement
---	------	--

**OK TO ROCK

Comments: