

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210630
Address: 2052 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Robb Popp	Failed	Wednesday, January 12, 2022

Corrective Action Required:

1	Misc	-Restore erosion control at perimeter and clean mud and debris from street before any further inspections
		-Obtain irrigation permit and backflow certification
		-Driveway inspection pending
		-Final grade and sod
		-Gutters, downspouts and downspout and sump extensions
		-Complete discharge line at dishwasher
		-Complete spindles at stairway
		-Complete DWV for master shower drain

Comments: