

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210596
Address: 2102 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Wednesday, January 12, 2022

Corrective Action Required:

2	Misc	<ul style="list-style-type: none">- as graded plot plan- Address grade in back- Spark ring required at floor outlet near stairs- Provide code complaint Hand rail in garage- Sump discharge 27" above grade- Final grading and sod- Submit back flow certification- Pay all fees- Provide splash blocks
---	------	---

Comments: