

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211217
Address: 2101 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Wednesday, January 12, 2022

Corrective Action Required:

1	Misc	-Final grade and sod -set water meter to grade, maintain 14"-18" clearance from top of meter to lid -complete spindles basement stairs -Install locking hardware sliding glass door, (2) locking devices required at sliding glass door -Garage door must be self closing -security screws at basement walkout -fireblock tub trap west side of basement
---	------	--

Comments: