CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20210263 Address: 520 NW HOPE LN, Unit:IR, LEES SUMMIT, MO 640811801 NW OBRIEN RD, LEES SUMMIT, MO 64081520 NW HOPE LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspectio	n:	Inspector:	Outcome:	Date:
Sanitary Sewer Construction Inspection		Ronald Paynter	Partial	Wednesday, January 12, 2022
Informati	onal:			
1	Misc	Main was cut and a wye was inserted and connected with max adapters. Service lateral and tracer wire were placed. Building connection was completed with a hard back fernco. RP 1-12-22		

Comments: