

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210744
Address: 2155 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Wednesday, January 12, 2022

Corrective Action Required:

1	Misc	-Complete Final grade and sod -Splash blocks and sump pump discharge 36" from foundation -check water meter and siding from grade at time of final grade and sod -outlet required at counter space right and left of fireplace -rear sliding door hardware to be completed -outlet in downstairs kitchen area on west wall needs GFCI protection -wall counter space in basement great room requires outlets per code -back patio lights must comply with security code section 7-1409.2 -(2)1/2" through bolts required at each post to beam connection.
---	------	---

Comments: