

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213183
Address: 2106 SW RUTHERFORD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Patrick Schonfeldt	Failed	Tuesday, January 04, 2022

Corrective Action Required:
1 Misc -GAS LINE BOND REQUIRED

****GAS PRESSURE OK****

Corrective Action Required:
2 Misc -GAS LINE BOND REQUIRED

****GAS PRESSURE OK****

Comments: