

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191614
Address: 1701 SE OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Robb Popp	Partial	Thursday, January 13, 2022

Informational:

1	Misc	Kitchen ok for skirts at dishwasher and hood
---	------	--

Corrective Action Required:

2	Misc	KITCHEN AREA:--NEED TO VERIFY ACCESS PANELS, OK FOR TILE
---	------	--

Comments: