

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20212478  
Address: 3200 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Thursday, January 13, 2022

Informational:	
1 Misc	-GARAGE PORTAL EXTERIOR ONLY OK TO COVER
Corrective Action Required:	
2 Misc	-ADDRESS OVERBORED STUD FOR SE CABLE IN GARAGE MUST BE FIXED TO ENGINEER LETTER REQUIRMENTS -Install sliding glass door
	Okay to insulate

**Comments:**