

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRPR20215531  
Address: 1801 NW CHIPMAN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                        | Inspector:      | Outcome: | Date:                      |
|------------------------------------|-----------------|----------|----------------------------|
| <b>Final Mechanical Inspection</b> | Michael Harkins | Failed   | Thursday, January 13, 2022 |

| Corrective Action Required: |   |
|-----------------------------|---|
| 1                           | Miscellaneous Correction  |
|                             | REFRIGERANT CIRCUIT ACCESS PORTS LOCATED OUTDOORS SHALL BE FITTED WITH LOCKING TYPE TAMPER RESISTANT CAPS ( 2018 IMC 1101.10)<br>PROVIDE CLAMP ON AC WHIPS<br>PROVIDE COVER OPEN J BOX AT FURNACE |

**Comments:**