

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212857

Address: 3807 SW WALSH DR, LEES SUMMIT, MO 640823803 SW WALSH DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Friday, January 14, 2022

Corrective Action Required:

1	Misc	INSPECTION DENIED
---	------	-------------------

PLANS NEED TO BE REVISED AND SUBMITTED FOR APPROVAL BY DEVELOPMENT SERVICES TO INCLUDE CHANGES TO RATED PARTY WALL DESIGN, PLANS SHOULD INCLUDE UL # AND DESCRIPTION OF UL DESIGN, SPACING OF CLIPS, STAMPED BY ENGINEER OF RECORD

1/14/22 - APPROVED REVISED PLANS REQUIRED ON SITE BEFORE PERFORMING ALL ROUGH

Comments: