

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20210533
Address: 838 SW BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Michael Harkins	Failed	Friday, January 14, 2022

Corrective Action Required:

1	Miscellaneous Correction	Complete rubber cove base restrooms & kitchen Complete drains & grease interceptor 3 compartment sink Provide GFCI protection receptacle next to 3 compartment sink Provide health dept inspection report
---	--------------------------	--

: OK to stock & train :

Comments: