

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20211738
Address: 2061 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Hood/Duct Inspection	Michael Harkins	Failed	Friday, January 14, 2022

Corrective Action Required:

1	Miscellaneous Correction	BIG DOUBLE HOOD REPAIR MARKED PINHOLES IN WEST DUCT & EAST DUCT, COMPLETE ELBOWS TO ROOF EAST DUCT. DROP 100 WATT LIGHT FROM ROOF ALL 4 GREASE DUCTS
---	--------------------------	---

Comments: