

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20202637
Address: 1001 SE BAILEY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Robb Popp	Partial	Tuesday, January 18, 2022

Corrective Action Required:

1	THE FOLLOWING AREAS ARE APPROVED	<p>-SOFFITS AT: CLEAR STORY A100, B100A -HARD LIDS AT A213, B114, 121A, B113, C100A ,,B115,B117,C101A,C10,C10A,C129,C127,C121,C115D,C102-C104, C208, C214, C20</p> <p>BUILDING A: A111,A113, A101, A103, A104, A105, A106 A108,A108A,A110,A110A,117A,117B,118,118B A202, 203, 204, 205, 207, 208, 209, 210</p> <p>BUILDING B: 101-103, 105-108, 110, 110A, 111,112, 117,118, 121, 121C, 122, 201-206, 208, 209, 211, 212, 214A, 215, 216, 216A</p> <p>B113,B115, B121C, B121D, B122, B121, B121B, B120, B119 B212, B201, B203, B204-OK FOR BORDERS</p> <p>BUILDING C: C102, C104. C129, C129A, C129B, C131, C130, C128, C126, C125, C124, C122, C123, C120, C119, C118, C117, C115, C115A, C115B, C115C, C101, C106, C107, C108, C109,C219, C219A, C219B, C219C, C217A, C217C, C217B, C216, C216B, C210, C211, C212, C201, C202, C203, C204, C206, C207 OK FOR BORDERS</p>
---	----------------------------------	--

Corrective Action Required:

2	Misc	A218, A218A- OPEN J BOXES B210- OPEN J BOX B214- OPEN J BOX, EXHAUST HOOD, MISSING (2) TIE WIRES AT MAIN
---	------	--

Comments: