

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211762
Address: 4724 NE FREEHOLD DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Tuesday, January 18, 2022

Corrective Action Required:

1	Misc	-Install ceiling beam hanger above foyer -Nail king stud to master bedroom window header -Move smoke alarm outside master bedroom higher -Nail ceiling beam hanger above rear dining corner -Anchor sill plate within 12" of break at stair; at rear corner of basement family room; at rear basement bedroom -Provide min 12" horizontal clearance from light to basement closet storage space
---	------	--

****OK TO INSULATE**

Comments: