

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20212482  
Address: 3129 SW ARBORTREE DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mitchell Schwarz	Failed	Tuesday, January 18, 2022

Corrective Action Required:

1	Misc	-Final grade and sod -check water meter and siding from ground at time of final grade and sod -handrail height in garage to comply with code section R311.7.8.1
---	------	---

**Comments:**