CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204351

Address: 2529 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

All Rough Inspection - Shawn Hoffman Failed Tuesday, January 18,

Residential 2022

Corrective Action Required:

1 Miscellaneous Correction

- Nail exterior sheeting per code, bay window
- Nail off joist hangers at I-beam in pantry
- Through bolts on I- beam not to plan's
- Nail off corner dining room
- Land all electrical wiring
- Nail off corner pantry
- Security blocking back door, strike plate
- Fur out DWV at back door
- Address over bored joist living room
- Nail off corner by fire place
- Address over bored studs right of fire place
- Provide 2 1200 lb straps bay window per plan
- Complete though bolts above formal dining
- Address over bored joist front closet
- Fur out pipes in front closet
- Strap stud breaks sides windows stair landing
- Address siding gaps bedroom 4 at WIC
- Provide joist hangers for joist over 4' basement
- Insulate and block cantilevers in basement

Comments: