

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20191614  
Address: 1701 SE OLDHAM PKWY, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Robb Popp	Partial	Tuesday, January 18, 2022

Informational:

1	Misc	Kitchen ok for skirts at dishwasher and hood Memory Care corridors approved except as noted, room 21 approved
---	------	--

Corrective Action Required:

2	Misc	KITCHEN AREA:--NEED TO VERIFY ACCESS PANELS, OK FOR TILE MC AREA: CORRIDOR 34,39 DAMPERS, ROOM 25, 22 SEAL PENETRATIONS, COMPLETE MECHANICAL
---	------	--

**Comments:**