

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20204172  
Address: 3207 SW PERGOLA PARK DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Shawn Hoffman	Failed	Tuesday, January 18, 2022

Corrective Action Required:

1	Misc	-All windows larger than 9 sq ft and less than 18" above finish floor shall be safety tempered glass windows -Deck not inspected at rough in
---	------	---

Corrective Action Required:

2	Miscellaneous Correction	- Lock and secondary lock on front door - Nail hangers on deck joist - Provide 2 1/2" through bolts for all post to beam connections at deck - Final grading and sod - Garage door shall be self closing - Address water meter height to grade - remove dust covering from smoke detector top of stairs - provide pier inspection for deck
---	--------------------------	---

**Comments:**