

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213955

Address: 2103 SW OSAGE DR, LEES SUMMIT, MO 640822105 SW OSAGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Service Inspection - R	Patrick Schonfeldt	Failed	Tuesday, January 18, 2022

Corrective Action Required:

1	Misc	2103 OK
		2105 - ADJUST HEIGHT, 14"-18" FROM TOP OF METER TO TOP OF LID

Comments: