

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211706
Address: 2349 SW OLD PORT RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Tuesday, January 18, 2022

Corrective Action Required:

1	Misc	<p>*Revise plans to show what is load bearing and what is not*</p> <ul style="list-style-type: none">-remove all roof supports from non bearing walls-provide hip legs at hip over dining (revise plans to show hip not extending over bearing wall)-provide mechanical strap where top plate does not intersect with other walls back wall-address Lvl above dining/great room plans show extending past coat closet-anchor bolts to be tight, in the middle 1/3 of bottom plate-seal penetrations in vertical to horizontal fire blocking-anchor bolts to be in the middle third of. Bottom plate in basement-Fire block furred down end east wall basement
---	------	--

Comments: