

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20214854  
Address: 821 SW LEMANS LN, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Patrick Schonfeldt	Failed	Wednesday, January 19, 2022

Corrective Action Required:

1	Misc	SEE FIRE INSPECTION REPORT FOR CORRECTIONS  -REMOVE OR TERMINATE OPEN MC ABOVE SERVICE PANEL IN MECH ROOM , ADD COVER PLATE ON J BOX ABOVE MECH STORAGE ROOM AND SECURE MC OFF CEILING GRID - COVER PLATES ON SWITCHES -HAVE PLUMBER PULL PERMIT FOR ADDITONAL WORK BEING DONE IN BREAK ROOM
---	------	---

Comments: