

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213683
Address: 4816 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|--------------|----------|--------------------------------|
| All Rough Inspection - Residential | Khanh Nguyen | Failed | Wednesday, January 19, 2022 |

Corrective Action Required:

| | | |
|---|-----------------------------|--|
| 1 | Miscellaneous Correction | -Shim gaps under studs in garage -Seal penetrations of ceiling joist return air space in basement |
|---|-----------------------------|--|

****THANK YOU EVERSTEAD ENGINEERING**

Comments: