

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20211738
Address: 2061 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Hood/Duct Inspection	Michael Harkins	Failed	Wednesday, January 19, 2022

Corrective Action Required:

1 Misc

WELDS APPROVED FOR 1ST LAYER WRAP

1ST LAYER FAIL PROVIDE CLEARANCES OR CONTINUOUSLY COVER ON ALL SIDES
WITH LISTED & LABELED FIELD APPLIED GREASE DUCT ENCLOSURE MATERIAL
(2018 IMC 506.3.6)

Comments: