

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210556
Address: 326 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Wednesday, January 19, 2022

Corrective Action Required:

- | | | |
|---|--------------------------|---|
| 1 | Miscellaneous Correction | <ul style="list-style-type: none">- Pantry door must be self closing and latch- Counter space both sides of fire place require outlet. E3901.4.1- Remove Dust covering on smoke alarm upstairs middle bedroom- Provide steps for Egress window |
| | | Handrail in garage not compliant with code R311.7.8.5 |
| | | <ul style="list-style-type: none">- Complete final grading and sod- Provide splash blocks |

Comments: