

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211218
Address: 127 NW JOSHUA DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Wednesday, January 19, 2022

Corrective Action Required:

1	Miscellaneous Correction	Submit back flow certification Provide sod Provide splash blocks Sump shall discharge 36" from foundation Seal top of ac disconnect & gas line at meter Provide GFCI protection for dishwasher
---	-----------------------------	---

Comments: