

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary

Certificate of Occupancy

Permit #: **PRRES20210744**
Address: **2155 NW KILLARNEY LN, LEES SUMMIT, MO 64081**
Inspected On: **Wednesday, January 19, 2022**
Inspected By: **Shawn Hoffman**
Expiration Date: **3/18/2022 12:00:00 AM**

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Temporary C of O	Wednesday, January 19, 2022

Corrective Action Required:

1	Misc	-Complete Final grade and sod -Splash blocks discharge 36" from foundation -check water meter and siding from grade at time of final grade and sod -(2)1/2" through bolts required at each post to beam connection.
---	------	--

TCO expiration 3/18/22