

















HOME BUYER:	PHONE:	DATE DRAWN:	PLAN NO.	SHEET NO. 1
BUILDER:	PHONE:	DATE REVISED:	SF-7027	
SUB-DIVISION:	LOT NO.	DESIGNER:	FILE NAME:	APPROX. SQ.FT.
			7027 FRNT	

BUILDER/CONTRACTOR IS RESPONSIBLE TO CHECK ALL DIMENSIONS FOR ACCURACY BETWEEN FLOORS, FOUNDATION AND ELEVATIONS ALSO VERIFY ALL BEAM HEADERS, FAD LOCATIONS, AND COLUMN SIZES. BUILDER/CONTRACTOR TO CHECK FOR COMPLIANCE WITH CONTRACTS, CITY, AND NATIONAL CODES. BUILDER/CONTRACTOR ACCEPTS ALL RESPONSIBILITY FOR LOT PLACEMENT, SET-BACKS, AND FLOOD PLANS. BUILDER/CONTRACTOR AND HOME OWNER ACCEPTS RESPONSIBILITY FOR ANY AND ALL COPYRIGHT INFRINGEMENTS OR RESEMBLANCES TO OTHER COPYRIGHTED PLANS. BUILDER/CONTRACTOR ACCEPTS RESPONSIBILITY FOR ANY ON SITE CHANGES MADE TO STRUCTURE.



REQUIRED FOOTING:			
BUILDING HEIGHT	MINIMUM FOOTING	HORIZONTAL REBAR	LOCATION OF REBAR
1 OR 2 STY.	8" X 16"W	2-#4	5" FROM BTM.
3 STORY	8" X 24"W	2-#4	5" FROM BTM.
ACC. STR.	8" X 12"W	2-#4	5" FROM BTM.



ALL NOTES, SECTIONS, AND DRAWINGS
ARE IN ACCORDANCE WITH THE 2018 IRC

BASEMENT PLAN
 $1/4" = 1'0"$

SITE ADDRESS:
205 NW AMBERSHAM DR.
LEE'S SUMMIT, MO

[illegible]

HOME BUYER:

BUILDER:

SUB-DIVISION:

PHONE:

PHONE:

LOT NO.

DATE DRAWN:

DATE REVISED:

DESIGNER:

PLAN NO.


ELL E NAME:

FILE NAME: 7007 BCMT


SHEET NO.

76

1. $\frac{1}{2}$




TYPICAL WALL SECTION




EXTERIOR TALL WALL SECTION


10' TALL 10" TALL WALLS UNINTERRUPTED TO BE CONSTRUCTED WITH 2X6 STUDS 16" O.C. WITH STIFF BACK EVERY 48" O.C.




FOUNDATION WALL JUMP DETAIL



STAIR SECTION (TYP)




TYPICAL CANTILEVER FRAMING W/ DECK ATTACHMENT




UPSET STEEL BEAM/JOIST CONNECTION

DECK JOIST SPAN	1/2" O LAG SPACING	EQUIVALENT SPACING FOR 16" O.C. JOIST BAYS
UP TO 10'-0"	16" O.C.	N/A
10'-0" - 14'-0"	12" O.C.	16" O.C. DBL EVERY OTHER
14'-0" - 18'-0"	8" O.C.	16" O.C. DBL EVERY JOIST BAY



HSS COLUMN DETAIL




FIRST FLOOR PLAN

1/4" = 1'0"

BEARING WALL LINES


ALL NOTES, SECTIONS, AND DRAWINGS ARE IN ACCORDANCE WITH THE 2018 IRC

BUILDER/CONTRACTOR IS RESPONSIBLE TO CHECK ALL DIMENSIONS FOR ACCURACY BETWEEN FOUNDATION, FLOORING, AND ELEVATIONS. ALSO VERIFY ALL BEAM HEADERS, COLUMNS, AND COLUMN SIZES. BUILDER/CONTRACTOR TO CHECK FOR CONFLICTS BETWEEN ALL DIMENSIONS AND ELEVATIONS. BUILDER/CONTRACTOR TO CHECK FOR CONFLICTS BETWEEN ALL DIMENSIONS AND ELEVATIONS. BUILDER/CONTRACTOR TO CHECK FOR CONFLICTS BETWEEN ALL DIMENSIONS AND ELEVATIONS.



SITE ADDRESS: 205 NW AMBERSHAM DR. LEE'S SUMMIT, MO

HOME BUYER:	PHONE:	DATE DRAWN:	PLAN NO.	SHEET NO.
BUILDER:	PHONE:	DATE REVISED:	9F-7027	3
SUB-DIVISION:	LOT NO.	DESIGNER:	FILE NAME:	APPROX. SQ.FT.
			7027 FLR1	



TYPICAL METAL FIRE PLACE

NOTE:SEE SPECS FOR SPECIFIC APPLICATIONS.




TYPICAL F.P. FRONT

2 - 2X6 PURLINS WHERE SHOWN, MAINTAIN RAFTER
HORIZONTAL SPAN 12' OR LESS. 2 - 2X4 TEE PURLIN
BRACES AT 40\"/>

2 - 2X4 TEE PURLIN BRACES (MAX LENGTH OF 10'
(2X4 W/ 2X6 TEE FOR BRACE 10' - 14')

NOTE: HIP RIDGE FOR THE MAIN ROOF AS:
2X8 FOR UNBRACED LEGTH UP TO 9'0"
2X10 FOR UNBRACED LENGTH UP TO 10'0"
2X12 FOR UNBRACED LENGTH UP TO 12'0"
ALL RAFTERS TO BE #2 2X6 D-FIR 16\"/>



ROOF ELEVATION

1/4" = 1'0"

ROOF DESIGNED WITH:
LIVE LOAD = 20 PSF
DEAD LOAD = 10 PSF

SITE ADDRESS:
205 NW AMBERSHAM DR.
LEE'S SUMMIT, MO

BUILDER/CONTRACTOR IS RESPONSIBLE TO CHECK ALL DIMENSIONS FOR ACCURACY
BETWEEN FLOORS, FOUNDATION AND ELEVATIONS. ALSO VERIFY ALL BEAM, HEATERS,
AND LOCATION, AND COLUMN SIZES. BUILDER/CONTRACTOR TO CHECK FOR
CONFLICTS WITH EXISTING STRUCTURE. BUILDER/CONTRACTOR TO VERIFY
ACCEPTS ALL RESPONSIBILITY FOR ALL LOT PLACEMENT, SETBACKS, AND PLANS.
BUILDER/CONTRACTOR AND HOME OWNER ACCEPTS RESPONSIBILITY FOR ANY AND ALL
COPYRIGHT INFRINGEMENTS OR RESUBMISSIONS TO OTHER COPYRIGHTED PLANS.
BUILDER/CONTRACTOR ACCEPTS RESPONSIBILITY FOR ANY ON SITE CHANGES MADE
TO STRUCTURE.

HOME BUYER:

BUILDER:

SUB-DIVISION:

PHONE:

PHONE:

LOT NO.

DATE DRAWN:

DATE REVISED:

DESIGNER:

PLAN NO.

9F-7027

FILE NAME:

7027 ROOF

SHEET NO.

4

APPROX. SQ.FT.

GENERAL NOTES

WINDOW SIZES SHOWN ARE APPROXIMATE. THE BUILDER SHALL SELECT WINDOWS TO MEET BUILDING CODE REQUIREMENTS AND TO FIT IN THE AVAILABLE SPACE. OVERALL ROUGH OPENINGS FOR MULLED UNITS WILL VARY BY WINDOW/ DOOR MANUFACTURER.

EXTERIOR WALLS ARE 2x4 STUDS AT 16" O.C. UNLESS OTHERWISE NOTED.

GARAGE
THE GARAGE FLOOR SHALL BE SLOPED TOWARD GARAGE DOORS DOORS BETWEEN GARAGE AND DWELLING - MIN 1/8" SOLID CORE OR HONEY COMBED STEEL DOOR OR 20 MIN. RATED. GARAGE TO HAVE 5/8" TYPE X GYPSUM THROUGHOUT THE H-FRAME SHALL CONSIST OF 2x6 FRAMING

GLAZING
GLAZING IN HAZARDOUS LOCATIONS AS IDENTIFIED IN 2010 IRC SHALL BE APPROVED SAFETY GLAZING MATERIALS: GLASS IN STORM DOORS, INDIVIDUAL FIXED OR OPENABLE PANELS ADJACENT TO A DOOR WHERE THE NEAREST VERTICAL EDGE IS WITHIN A 24" ARCH OF THE DOOR IN CLOSED POSITION AND WHOSE BOTTOM EDGE IS WITHIN 60" OF THE FLOOR; WALLS ENCLOSED STAIRWAYS AND LANDINGS WHERE THE GLAZING IS WITHIN 60" OF THE TOP OR BOTTOM OF THE STAIR ENCLOSURES FOR SPAS, TUBS, SHOWERS, AND WHIRLPOOLS; GLAZING IN FIXED OR OPENABLE PANELS EXCEEDING 9' 50. FT. AND WHOSE BOTTOM EDGE IS LESS THAN 10" ABOVE THE FLOOR OR WALKING SURFACE WITH IN 36"

EMERGENCY EGRESS
PROVIDE ONE WINDOW FROM EACH BEDROOM THAT HAS A MIN. OPENABLE AREA OF 5.7 SQ. FT. WITH A MIN. OPENABLE HEIGHT OF 24" AND WIDTH OF 21"

ELECTRICAL OUTLETS
ALL OUTLETS TO BE ARC FAULT CIRCUIT-INTERRUPTER OR GROUND FAULT CIRCUIT-INTERRUPTER PROTECTED EXCEPT. REFRIGERATOR, SINGLE OUTLET FOR SUMP PUMP AND SINGLE OUTLET IN GARAGE FOR A FREEZER
ALL OUTLETS TO BE TAMPER RESISTANT

CARBON MONOXIDE ALARMS
CARBON MONOXIDE ALARMS FOR NEW CONSTRUCTION. AN APPROVED CARBON MONOXIDE ALARM SHALL BE INSTALLED OUTSIDE OF EACH SEPARATE SLEEPING AREA IN THE IMMEDIATE VICINITY OF THE BEDROOMS IN DWELLING UNITS WITHIN WHICH FUEL-FIRED APPLIANCES ARE INSTALLED AND IN DWELLING UNITS THAT HAVE ATTACHED GARAGE.

CARBON MONOXIDE DETECTION SYSTEMS
CARBON MONOXIDE DETECTION SYSTEMS THAT INCLUDE CARBON MONOXIDE DETECTORS AND AUDIBLE NOTIFICATION APPLIANCES, INSTALLED AND MAINTAINED IN ACCORDANCE WITH THIS SECTION FOR CARBON MONOXIDE ALAMS AND NFPA 720, SHALL BE PERMITTED. THE CARBON MONOXIDE DETECTORS SHALL BE LISTED AS COMPLYING WITH UL 2070, WHERE A HOUSEHOLD CARBON MONOXIDE DETECTION SYSTEM IS INSTALLED, IT SHALL BECOME A PERMANENT FEATURE OF THE OCCUPANCY, OWNED BY THE HOMEOWNER AND SHALL BE MONITORED BY AN APPROVED SUPERVISING STATION.

GUARD OPENING LIMITATIONS
REQUIRED GUARDS ON OPEN SIDES OF STAIRWAYS, RAISED FLOOR AREA, BALCONIES, AND PORCHES SHALL HAVE INTERMEDIATE RAILS OR ORNAMENTAL CLOSURES THAT DO NOT ALLOW PASSAGE OF A SPHERE 4" OR MORE IN DIAMETER

OPENING PROTECTION
OPENING FROM A PRIVATE GARAGE DIRECTLY INTO A ROOM USED FOR SLEEPING PURPOSES SHALL NOT BE PERMITTED. OTHER OPENINGS BETWEEN THE GARAGE AND RESIDENCE SHALL BE EQUIPPED WITH SOLID WOOD DOORS NOT LESS THAN 1 3/8" IN THICKNESS, SOLID OR HONEYCOMB-CORE STEEL DOOR NOT LESS THAN 1 3/8" THICK, OR 20 MINUTE FIRE-RATED DOORS, EQUIPPED WITH A SELF-CLOSING DEVICE.

SMOKE ALARMS
PROVIDE SMOKE ALARMS IN EACH SLEEPING ROOM, OUTSIDE OF EACH SLEEPING ROOM AND ON EACH FLOOR, INCLUDING BASEMENT. ALARMS SHALL BE INTERCONNECTED IN SUCH A MANNER THAT THE ACTIVATION OF ONE ALARM WILL ACTIVATE ALL OF THE ALARMS IN THE DWELLING.

FRAMING NOTE

ALL LUMBER SIZES ARE FOR #2 D-FIR-LARCH ALL HEADERS TO BE MIN. (2) #2 D201 BLOCK CANTILEVERS, DOOR JAMBS, AND OVER BEAMS ALL HEADRS TO BEAR ON MIN. OF (2) 2X4 STUDS JOIST UNDER BEARING PARTITIONS SHALL BE DOUBLED AND COMPLY WITH 2010 IRC WATER-RESISTIVE BARRIER SHALL BE PROVIDED OVER ALL EXTERIOR WALLS PER 2010 IRC ROOF PLAN NOTES ALL ROOF RAFTERS NOT CALLED OUT ARE TO BE 2x6 SPT #1/#2 @ 16". ALL CEILING JOISTS NOT CALLED OUT ARE TO BE 2x6 SPT #1/#2 @ 16". ALL VAULTS TO BE PURR DOWN W/2x MATERIAL TO PROVIDE FOR R-9.9 INSULATION ALL EXTERIOR AND LOAD BEARING WINDOW AND DOOR HEADERS TO BE (2) 2x6 DFR #2 UNLESS NOTED OTHERWISE ON PLANS ALL RIDGES, HPs, AND VALLEYS NOT MARKED SHALL BE (1) NOMINAL SIZE LARGER THAN THE INTERSECTING RAFTERS CEILING JOISTS AND RAFTERS SHALL BE NAILED TO EACH OTHER WITH (3) 16d COM (3 1/2"x0.162") NAILS AND THE RAFTER SHALL BE NAILED TO THE TOP WALL PLATE WITH (3) 8d COM (2 1/2"x0.191") NAILS. CEILING JOISTS SHALL BE CONTINUOUS OR SECURELY JOINED WITH (3) 16d COM (3 1/2"x0.162") NAILS WHERE THEY MEET OVER INTERIOR PARTITIONS AND ARE NAILED TO ADJACENT RAFTERS TO PROVIDE A CONTINUOUS TIE ACROSS THE BUILDING WHEN SUCH JOISTS ARE PARALLEL TO THE RAFTERS. WHERE CEILING JOISTS ARE NOT CONNECTED TO THE RAFTERS AT THE TOP WALL PLATE (w/ AT LOCATIONS WHERE C.J. ARE PERPENDICULAR TO RAFTERS), INSTALL 2x4 RAFTER TIES, IN THE LOWER 1/3 OF ATTIC SPACE @ 16" WITH (3) 16d COM (3 1/2"x0.162") NAILS EX. END. COLLAR TIES SHALL BE PROVIDED IN THE ATTIC SPACE IN THE UPPER 1/3 OF ATTIC RAFTER CONNECTIONS DESIGNED TO RESIST UPLIFT FORCES PER 2010 IRC TABLE 602.1. ROOF HEADERS DO NOT HAVE NOTABLE UPLIFT TO REQUIRE HOLD DOWNS. PROVIDE METAL FLASHING AT ALL ROOF VALLEYS. ROOF AND SOFFIT VENTS PER LOCAL CODES. WHERE POSSIBLE, PROVIDE ROOF VENTING ON BACK SIDE OF ROOF. EXACT GUTTER AND DOWNSPOUT LOCATION BY GUTTER INSTALLER. ROOF IS DESIGNED FOR 20 P.S.F. ROOF SNOW LOAD (MIN) MIN 20 YR. ASPHALT SHINGLES RAFTER TIES SHALL NOT BE REQUIRED WHEN A STRUCTURAL RIDGE HAS BEEN PROVIDED AND ADEQUATELY DESIGNED (AS IN A FULLY VAULTED ROOM) SUCH SHALL BE NOTED AS "STRUCTURAL" ON THE PLAN. PER 2010 IRC

ROOF BRACING
ROOF FURLING TO BE PLACED APPROXIMATELY WHERE SHOWN ON ROOF FURLING. USE 2x6 STUD GRADE FURLIN PLACED PERPENDICULAR TO RAFTERS (UNLESS NOTED OTHERWISE ON PLANS) RIDGE, HP, VALLEY, AND FURLIN BRACE STRUTS TO BE PLACED AS SHOWN ON PLANS. STRUTS TO BE 2x4 STUD GRADE W/ MAXIMUM UNBRACED LENGTH OF 8'-0" AND AT A 45° ANGLE W/ HORIZONTAL OR GREATER (VERTICAL WHERE POSSIBLE) BRACES LONGER THAN 8'-0" SHALL BE 2x4 STRONG BACK BRACES

EXCEPTIONS:
WINDOWS WHOSE OPENINGS WILL NOT ALLOW A 4" DIAMETER SPHERE TO PASS THROUGH THE OPENING WHEN THE OPENING IS IN ITS LARGEST OPENED POSITION. OPENINGS THAT ARE PROVIDED WITH WINDOW FALL PREVENTION DEVICES, WHICH COMPLY WITH ASTM F 2090. WINDOWS THAT ARE PROVIDED WITH WINDOW OPENING CONTROL DEVICES THAT COMPLY WITH SECTION R312.2.2

EXHAUST AIR
BATHROOMS, WATER CLOSET COMPARTMENTS AND OTHER SIMILAR ROOMS SHALL BE PROVIDED WITH AGGREGATE GLAZING AREA IN WINDOWS OF NOT LESS THAN 3 SQUARE FEET, ONE-HALF OF WHICH MUST BE OPERABLE
EXCEPTION:
THE GLAZED AREAS SHALL NOT BE REQUIRED WHERE ARTIFICIAL LIGHT AND A LOCAL EXHAUST SYSTEM ARE PROVIDED. THE MINIMUM LOCAL EXHAUST RATE SHALL BE DETERMINED IN ACCORDANCE WITH SECTION M607.1. EXHAUST AIR FROM THE SPACE SHALL BE EXHAUSTED DIRECTLY TO THE OUTDOORS

BRIDGING
JOISTS EXCEEDING A NOMINAL 2" X 12" SHALL BE SUPPORTED LATEROALLY BY SOLID BLOCKING, DIAGONAL BRIDGING (WOOD OR METAL), OR A CONTINUOUS 1" X 5" STRIP NAILED ACROSS THE BOTTOM OF THE JOIST PERPENDICULAR TO JOIST AT INTERVALS NOT EXCEEDING 8 FEET

WINDOW AND DOOR NOTES

1. ALL WINDOWS ARE SHOWN IN FEET (IE 3'0"0" IS A 3'0"x6'0" WINDOW). ALL DOORS SHOWN IN FEET AND INCHES (IE 2'0"0" DOOR IS A 2'-0"x6'-0" DOOR). CONTRACTOR/INSTALLER TO VERIFY R.O. DIMENSIONS WITH BUILDER SUPPLIED CUT SHEET PRIOR TO FRAMING.
2. ALL WINDOWS TO BE LOW-E GLASS TO MEET ALL LOCAL ENERGY CODE REQUIREMENTS.
3. PROVIDE EGRESS WINDOW IN ALL SLEEPING ROOMS. WINDOWS SHALL COMPLY WITH THE FOLLOWING:
A. MINIMUM OPEN AREA 5.7 SQ.FT.
B. MINIMUM OPENING HEIGHT 24 INCHES
C. MINIMUM OPENING WIDTH 20 INCHES
D. SILL HEIGHT 44" MAX ABOVE FLOOR
4. ALL WINDOW SILLS ARE TO BE 24" MIN ABOVE FINISH FLOOR, OR SHALL BE FIXED/NONOPERABLE
5. ALL WINDOWS AND GLAZED DOORS SHALL COMPLY WITH IRC SECTION R308.4. GLAZING IN HAZARDOUS LOCATIONS SHALL BE OF APPROVED SAFETY GLAZING MATERIALS. GLASS IN STORM DOORS, INDIVIDUAL FIXED OR OPERABLE PANELS ADJACENT TO A DOOR WHERE THE NEAREST VERTICAL EDGE IS WITHIN A 24" ARC OF THE DOOR IN A CLOSED POSITION AND WHOSE BOTTOM EDGE IS WITHIN 60" OF THE FLOOR. WALLS ENCLOSED STAIRWAYS AND LANDINGS WHERE THE GLAZING IS WITHIN 60" OF THE TOP OR BOTTOM OF STAIR ENCLOSURES FOR TUBS, SHOWERS AND WHIRLPOOLS. GLAZING IN FIXED OR OPERABLE PANELS EXCEEDING 9' 50" AND WHOSE BOTTOM EDGE IS LESS THAN 10" ABOVE THE FLOOR OR WALKING SURFACE WITHIN 36".
6. ALL OPERABLE WINDOWS SHALL HAVE FALL PROTECTION PER IRC R612.2.
7. ALL GLAZING IN WINDOWS AND DOORS SHALL COMPLY WITH THE TEST CRITERIA FOR CATEGORY I IN ACCORDANCE WITH CPSC 16 CFR 1201.
8. WINDOW MANUFACTURER TO CONFIRM EXACT SAFETY AND EGRESS WINDOW LOCATIONS PER LOCAL CODES.

GENERAL PLAN REQUIREMENTS

1. ALL STUD WALL FRAMING SHALL BE CONTINUOUS FROM THE FLOOR TO ROOF OR CEILING DIAPHRAGM. UNLO. ALL WALLS OVER 10'-0" ARE TO BE 2x6 @ 16". UNLO.
2. PROVIDE WATER-RESISTANT EXTERIOR WALL COVERING ON ALL FRAMED WALLS TO COMPLY WITH IRC SECTION 602.3.
3. PROVIDE GFCI ELECTRICAL OUTLETS ON EXTERIOR, IN UNFINISHED BASEMENT, IN BATHROOMS, ABOVE KITCHEN COUNTERS, IN GARAGE, AND WITHIN 6'-0" OF ANY SINK.
4. ALL EXTERIOR DOORS SERVED BY LANDING.
5. INSTALL CARBON MONOXIDE DETECTORS PER IRC SECTION 910 OUTSIDE OF EACH SLEEPING AREA.
6. INSTALL SMOKE DETECTORS IN EACH SLEEPING ROOM, OUTSIDE OF EACH SLEEPING AREA, WITH A MINIMUM OF ONE ON EACH FLOOR PER IRC SECTION 914.
7. PROVIDE A "UPER" GROUND PER IRC 360.0.1.
8. REFER TO WALL BRACE SHEET FOR ALL WALL BRACING DETAILS AND/OR CALCULATIONS.
9. INSTALL BLOCKING FOR TP HOLDERS, TOWEL BARS, AND TRIM BEAMS.
10. GARAGE DOOR H-FRAME: THE H-FRAME FOR ATTACHMENT OF THE GARAGE DOOR TRACK AND COUNTER BALANCE SHALL CONSIST OF THE FOLLOWING:
2x6 VERTICAL JAMBS RUNNING FROM FLOOR TO CEILING ATTACHED WITH 3/4"x1/2" NAILS @ 12". STAGGERED WITH (7) 3/4"x1/2" NAILS THRU JAMB INTO HEADER. MINIMUM 2x8 HEADER FOR ATTACHMENT OF COUNTER BALANCE SYSTEM
II. OVERHEAD GARAGE DOORS TO MEET 90 MPH WIND LOAD RESISTANCE REQUIREMENTS OF PASMA 10-B-9 AND ASTM E 530-02 PER IRC SECTION R 612.4.
12. MAXIMUM RISER HEIGHT OF STAIRWAYS SHALL NOT EXCEED 7 5/4". MAXIMUM RISER HEIGHT OF STAIRWAYS SHALL NOT EXCEED 7 5/4". THE TREADS SHALL PROVIDE A MINIMUM TREAD DEPTH OF 10".
13. ALL EXTERIOR AND LOAD BEARING WINDOW AND DOOR HEADERS TO BE (2) 2x6 DFR #2 UNLESS NOTED OTHERWISE ON PLANS
14. ALL HEADER BEARINGS (OTHER THAN WINDOWS) TO BE (2) 2x4 STUDS UNLESS NOTED OTHERWISE.
WINDOW HEADER BEARINGS TO BE (1) 2x4 EA END UNLESS NOTED OTHERWISE.

GENERAL FOUNDATION REQUIREMENTS

1. ALL FOOTINGS ARE TO BE EXTENDED TO MIN 36" BELOW FINISHED GRADE.
2. ALL INTERIOR FOOTINGS FOR LOAD BEARING WALLS AND COLUMNS SHALL BE ISOLATED FROM THE BASEMENT FLOOR SLAB.
3. FOR ALL CONC WALL OPENINGS, FOOTING 1 WALL STEPS, PROVIDE ONE #4 BAR, 48" LONG DIAGONALLY AS CLOSE AS PRACTICAL TO CORNER.
4. ALL REINFORCEMENT SHALL BE LAPPED A MIN OF 24" AT ENDS SPLICES AND AROUND CORNERS.
5. ANCHOR BOLTS ARE TO BE SPACED @ 36" WITH 7" MIN EMBED. A BOLT SHALL BE PLACED WITHIN 12" OF THE END OF EACH PLATE SECTION.
6. FASTEN JOISTS TO SILL PLATES WITH (3) 8d COM NAILS.
7. WHERE JOIST IS PARALLEL TO FOUNDATION, PROVIDE SOLID BLOCKING @ 32" FOR (3) JOIST SPACES. FASTEN TO SILL PLATE PER NOTE 6.
8. VAPOR BARRIER: 6 MIL PE VAPOR RETARDER WITH JOINTS LAPPED A MIN OF 6" BETWEEN SLAS 1. BASE.
9. DAMP PROOFING: ONE COAT (MIN) OF DAMP PROOFING OR EQUIVALENT FOUNDATION MEMBRANE SHALL BE APPLIED TO EXTERIOR WALL SURFACES BELOW GRADE. SEAL TIE HOLES, VOIDS BEFORE APPLICATION.
10. DRAINAGE DRAIN: INSTALL CONT 4" - PERFORATED PVC DRAIN TILE. DRAIN TILE TO BE EXTENDED TO SQUARE SUMP FIT WHICH EXTENDS A MIN 24" BELOW BASEMENT FLOOR.
II. ALL FRAMING MEMBERS IN CONTACT WITH CONCRETE SHALL BE ACQ TREATED LUMBER.
12. ALL STEEL FASTENERS (INCLUDING FOUND. ANCHOR BOLTS) ON ACQ TO BE (DOUBLE HOT-DIPPED) GALVANIZED.
13. PROVIDE A "UPER" GROUND PER IRC 360.01 WITH 1 "UPER" GROUND PER IRC 360.01.1. EGRESS WELL REQUIREMENTS:
A. IF THE VERTICAL DISTANCE FROM THE WINDOW SILL TO ADJACENT GRADE IS GREATER THAN 44", PROVIDE A LADDER.
B. ADD DRAIN TO DAYLIGHT OR SUMP PUMP.

ENERGY REQUIREMENTS

CONTRACTOR TO PROVIDE ENERGY AUDIT USING THE HERS ENERGY RATING SYSTEM. IN LIEU OF AN ENERGY AUDIT, THE FOLLOWING PRESCRIPTIVE REQUIREMENTS MAY BE FOLLOWED:
A. ALL DUCTS, AIR HANDLERS, FILTER BOXES, AND BUILDING ALL DUCTS, AIR HANDLERS, FILTER BOXES, AND BUILDING CAVITIES TO BE SEALED PER IRC SECTION N102.2.
B. THE BUILDING THERMAL ENVELOPE IS REQUIRED TO BE SEALED PER IRC SECTION N102.4.
C. CONTRACTOR TO SUBMIT "MANUAL J" AND "MANUAL D" CALCULATIONS FOR THE HVAC SYSTEM
D. INSULATION TO COMPLY WITH IECC AS FOLLOWS:
INSULATION TO COMPLY WITH IECC AS FOLLOWS:

WALLS	R-10
CEILING (PLAT)	R-40
CEILING (VAULTED)	R-50
	(NOTE: VAULTED AREA NOT TO 900+ H OR 20' OF ROOF AREA, WHICHEVER IS LESS)
FLOORS OVER UNCONDITIONED SPACE	R-10
CRAWL SPACE WALLS	R-10 (w/ R-10 CONTINUOUS)
BASEMENT WALLS	R-10 (w/ R-10 CONTINUOUS)
SLABS	N/R
DUCTWORK	R-8
WINDOWS	U 0.55 (MAX) SHGC 0.40 (MAX)
SKYLIGHTS	U 0.55 (MAX) SHGC 0.40 (MAX)

TABLE 602.3(1) FASTENER SCHEDULE FOR STRUCTURAL MEMBERS			
ITEM	DESCRIPTION OF BUILDING ELEMENTS	NUMBER AND TYPE OF FASTENERS N x n	SPACING OF FASTENERS
Roof			
1	Blocking between joist or rafter to top plate, toe nail	3-8d (2 1/2" x 0.1337)	---
2	Ceiling joists to plate, toe nail	3-8d (2 1/2" x 0.1337)	---
3	Ceiling joists not attached to parallel rafter, face over partition, face nail	3-10d (3" x 0.1387)	---
4	Collar tie to rafter, face nail or 1 1/4" x .25 edge ridge strap	3-10d (3" x 0.1387)	---
5	Rafter or roof truss to plate, toe nail	3-16d box nails (3 1/2" x 0.1387) or 3-16d common nails (3" x 0.1488)	2 toe nails on one side and 1 toe nail on opposite side of each rafter or truss
6	Roof rafters to ridge, valley or hip rafters: toe nail face nail	4-16d (3 1/2" x 0.1387) 3-16d (3 1/2" x 0.1387)	---
Wall			
7	Built-up studs-face nail	15d (3" x 0.1389)	24" o.c.
8	Abutting studs at intersecting wall corners, face nail	16d (3 1/2" x 0.1387)	12" o.c.
9	Built-up header, two pieces with 1/2" spacer	16d (3 1/2" x 0.1387)	16" o.c. along each edge
10	Continued header, two pieces	16d (3 1/2" x 0.1387)	16" o.c. along each edge
11	Continued header to stud, toe nail	4-8d (2 1/2" x 0.1337)	---
12	Double studs, face nail	15d (3" x 0.1389)	24" o.c.
13	Double top plates, minimum 24-inch offset of end joints, face nail in lapped area	4-16d (3 1/2" x 0.1387)	24" o.c.
14	Sole plate to joist or blocking, face nail	16d (3 1/2" x 0.1387)	16" o.c.
15	Sole plate to joist or blocking at braced wall panels	3-16d (3 1/2" x 0.1387)	16" o.c.
16	Stud to sole plate, toe nail	3-8d (2 1/2" x 0.1337) or 3-16d (3 1/2" x 0.1387)	---
17	Top or sole plate to stud, and nail	2-16d (3 1/2" x 0.1387)	---
18	Top plates, laps at corners and intersections, face nail	2-10d (3" x 0.1337)	---
19	1" brace to each stud and plate, face nail	2-8d (2 1/2" x 0.1337) 2 staples 1 1/2" x 1/4"	---
20	1" x 6" sheathing to each bearing, face nail	2-8d (2 1/2" x 0.1337) 2 staples 1 1/2" x 1/4"	---
21	2" x 8" sheathing to each bearing, face nail	2-8d (2 1/2" x 0.1337) 2 staples 1 1/2" x 1/4"	---
22	Wider than 1" x 3" sheathing to each bearing, face nail	3-8d (2 1/2" x 0.1337) 4 staples 1 1/2" x 1/4"	---
Floor			
24	Joist to sill or girder, toe nail	3-8d (2 1/2" x 0.1337)	---
25	Rim joist to top plate, toe nail (roof applications also)	8d (2 1/2" x 0.1337)	6" o.c.
26	Rim joist or blocking to sill plate, toe nail	8d (2 1/2" x 0.1337)	6" o.c.
27	1" x 6" subfloor or less to each joist, face nail	2-8d (2 1/2" x 0.1337) 2 staples 1 1/2" x 1/4"	---
28	2" subfloor to joist or girder, blind and face nail	2-16d (3 1/2" x 0.1387)	---
29	2" planks (plank & beam - floor & roof)	2-16d (3 1/2" x 0.1387)	at each bearing
30	Built-up girders and beams, 2-inch lumber layers	15d (3" x 0.1389)	as follows: 32" o.c. at top and bottom and staggered. Two nails at ends and at each splice.
31	Ledger strip supporting joists or rafter	3-16d (3 1/2" x 0.1387)	At each joist or rafter


TABLE 602.3(1) -continued FASTENER SCHEDULE FOR STRUCTURAL MEMBERS				
ITEM	DESCRIPTION OF BUILDING MATERIALS	DESCRIPTION OF FASTENER	Edges (inches) ^a	SPACING OF FASTENERS
Wood structural panels, subfloor, roof and interior wall sheathing to framing and particleboard wall sheathing to framing				
32	3/8" - 1/2"	8d common (2" x 0.1337) Nail (end nail only) 8d common nail (2 1/2" x 0.1337) Nail (roof)	6	12"
33	1/2" - 1"	8d common nail (2 1/2" x 0.1337)	6	12"
34	1 1/8" - 1 1/2"	16d common (3" x 0.1488) 8d (2 1/2" x 0.1337) Nail	6	12"
Other wall sheathing ^b				
35	1/2" structural cellular fibrousboard sheathing	1 1/2" galvanized roofing nail, 7/16" crown or 1" crown anule 14 ga., 1 1/2" long	3	6
36	5/8" structural cellular fibrousboard sheathing	1 1/2" galvanized roofing nail, 7/16" crown or 1" crown anule 14 ga., 1 1/2" long	3	6
37	1/2" gypsum sheathing	1 1/2" galvanized roofing nail, shade galvanized, 1 1/2" long, 1 1/2" crown, 1 1/2" x 1/4"	7	7
38	5/8" gypsum sheathing	1 1/2" galvanized roofing nail, shade galvanized, 1 1/2" long, 1 1/2" crown, 1 1/2" x 1/4"	7	7
Wood structural panels, combination subfloor underlayment to framing				
39	3/4" and less	8d deformed (2" x 0.1207) Nail 8d common (2 1/2" x 0.1337)	6	12"
40	7/8" - 1"	8d common (2 1/2" x 0.1337) Nail or 8-1007 nail	6	12"
41	1 1/8" - 1 1/4"	16d common (3" x 0.1488) Nail or 8d deformed (2 1/2" x 0.1337)	6	12"

For S1: 1 inch = 25.4 mm; 1 foot = 304.8 mm; 1 mile per hour = 0.447 m/s; 1 psi = 6.895 kPa.

Foundation Wall Reinforcement Schedule - Table 2

Vertical reinforcement spacing 60 psf soil									
Concrete strength/Grade Reinforcement #4 bar		8 inch thick wall			10 inch thick wall				
3,000 psi / Grade 40		16	12	NP	24	16	12		
3,500 psi / Grade 40		16	12	NP	24	24	12		
3,000 psi / Grade 60		24	16	NP	24	20	16		
3,500 psi / Grade 60		24	16	NP	24	24	16		
Horizontal reinforcement - Minimum Grade 40 Steel #4 bar									
One bar 12" from top of wall, maximum spacing 24" o.c.		4-#4	5-#4	6-#4	4-#4	5-#4	6-#4		

Footnotes:
1) Wall height is measured from the top of the wall to the top of the floor slab.
2) Vertical reinforcement for concrete walls that are not full height and for reinforcement spaced 24 inch on center may be placed in the middle of the wall. Other walls shall have vertical reinforcement placed as follows:
a) 8-inch wall - Minimum 5 inches from the outside face.
b) 10-inch wall - Minimum 5.75 inches from the outside face.
c) Extend bars to within 8 inches of the top of the wall.
3) Reinforcement clearances:
a) Concrete exposed to earth - minimum 1-1/2 inches.
b) Not exposed to weather (interior side of walls) - minimum 3/4 inch.
c) Concrete exposed to weather (top clearance in garage and driveway slabs)- 1-1/2 inches.
4) Horizontal reinforcement:
a) One bar shall be placed within 12 inches of the top of the wall.
b) Other bars shall be equally spaced with spacing not to exceed 24 inches on center.
c) Horizontal bars should be as close to the tension face as possible (interior) and behind the vertical reinforcement (i.e. 2" towards the inside).
d) Supplemental reinforcement at corners - Place 1 #4 bar 48 inches long at 45 degree angle at corners of openings per Figure 4a. Place reinforcement within 6" of the edge of inside corners.
5) Reinforcement shall be lapped a minimum 24 inches at ends, splices, and around corners.
6) At masonry ledges the minimum wall thickness shall be 5-12 inches. Ledges shall not exceed a depth of more than 24 inches below the top of the wall. For wall thicknesses less than 4 inches provide #4 bars at maximum 24 inches on center to within 8 inches of the top of the wall.
7) Straight walls more than 5 feet tall and more than 16 feet long shall be provided with exterior braced return walls. Wall length shall be measured using inside the shortest dimension between intersecting walls (See 752).



GENERAL REQUIREMENTS:

FLASHING OR ANOTHER APPROVED WEATHER RESISTIVE BARRIER SHALL BE PLACED BETWEEN THE CONCRETE PORCH STOOP AND THE DWELLING (IRC R319). THE WEATHER RESISTIVE BARRIER SHALL EXTEND UNDER THE WALL COVERING AND DOWN OVER THE EDGE OF THE FOUNDATION WALL TO FORM A CONTINUOUS BARRIER TO PREVENT WATER INTRUSION INTO THE BUILDING (IRC R703.0). PENETRATIONS, SEAMS, AND JOINTS SHALL BE EFFECTIVELY SEALER.
THE FLASHING AND SEALANTS SHALL FORM A PHYSICAL BARRIER TO RESTRICT ACCESS (IRC R320.1)

SUSPENDED PORCH STOOP DETAIL

SEE ELEVATION FOR WALL HEIGHTS

NOTE.. ELECTRICAL SERVICE TO BE 200 AMP.

NOTE.. DOUBLE JOIST UNDER ALL PARALLEL WALLS ABOVE UNLESS NOTED

S.D. = SMOKE DETECTOR

GENERAL HEADER SPECIFICATIONS:


REQUIRED AREAS NEEDING HEADERS:	HEADER DESCRIPTIONS:
WINDOWS/DOORS UP TO 38" R.O.	(2) #2 D-FIR 2X10'S
WINDOWS/DOORS 38" UP TO 72" R.O.	(2) #2 D-FIR 2X10'S W/1/2" GLUE PLY
WINDOWS/DOORS 72" UP TO 96" R.O.	(2) 9 1/2" L.V.L.
80" GARAGE DOORS W/CEILING & ROOF LOAD	(2) 9 1/2" L.V.L.
90" GARAGE DOORS W/CEILING & ROOF LOAD	(2) 9 1/2" L.V.L.
80" GARAGE DOORS W/SECOND FLOOR	(2) 9 1/2" L.V.L.
90" GARAGE DOORS W/SECOND FLOOR	(2) 11 7/8" L.V.L.
160" GARAGE DOOR WINDO SECOND FLOOR	(2) 11 7/8" L.V.L.
160" GARAGE DOORS W/SECOND FLOOR	(2) 14" L.V.L.

USE HEADERS FOR OPENINGS ABOVE UNLESS SPECIFIED OTHERWISE.

BUILDER/CONTRACTOR IS RESPONSIBLE TO CHECK ALL DIMENSIONS FOR ACCURACY BETWEEN FLOORS, FOUNDATION AND ELEVATIONS. ALSO VERIFY ALL BEAM HEADERS, AND LOCATIONS. BUILDER/CONTRACTOR SHALL BE RESPONSIBLE TO CHECK FOR CORRECT PLACEMENT OF ALL FASTENERS, AND TO VERIFY ALL FASTENERS ARE ACCEPTED AS RESPONSIBLE FOR ALL LOT PLACEMENTS, SETBACKS, AND ELEVATIONS. BUILDER/CONTRACTOR AND HOME OWNER AGENTS TO OTHER COPYRIGHTED PLANS. COPYRIGHT INFRINGEMENTS OR RESEMBLANCES TO OTHER COPYRIGHTED PLANS. BUILDER/CONTRACTOR ACCEPTS RESPONSIBILITY FOR ANY AND ALL SITE CHANGES MADE TO STRUCTURE.



SITE ADDRESS:
203 NW AMBERSHAM DR.
LEE'S SUMMIT, MO



BUILDER/CONTRACTOR IS RESPONSIBLE TO CHECK ALL DIMENSIONS FOR ACCURACY BEFORE FLOORING, FOUNDATION AND ELEVATIONS ALSO VERIFY ALL BEAM, HEADERS, JOIST LOCATIONS, AND COLUMN SIZES. BUILDER/CONTRACTOR TO CHECK FOR COMPLIANCE WITH CONTRACTS CITY, AND NATIONAL CODES. BUILDER/CONTRACTOR ACCEPTS ALL RESPONSIBILITY FOR LOT PLACEMENT, SET BACKS, AND FLOOD PLANNING. BUILDER/CONTRACTOR AND HOME OWNER ACCEPTS RESPONSIBILITY FOR ANY AND ALL COPYRIGHT INFRINGEMENTS OR RESSEMBLANCES TO OTHER COPYRIGHTED PLANS. BUILDER/CONTRACTOR ACCEPTS RESPONSIBILITY FOR AN ON SITE CHANGES MADE TO STRUCTURE.