

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212885
Address: 2114 SW RUTHERFORD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--------------------------------------|--------------------|----------|-----------------------------|
| Electrical Service Inspection | Patrick Schonfeldt | Failed | Wednesday, January 19, 2022 |

Corrective Action Required:
1 Misc -Install clamp listed for rebar to GEC at UFER, separation of dissimilar metals

Comments: