

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20212082  
Address: 1100 NE DOUGLAS ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Michael Harkins	Not Ready	Wednesday, January 19, 2022

Corrective Action Required:

1	Miscellaneous Correction	Provide spark rings GFCIs ( 2017 NEC 314.20 ) Provide ladder for roof access Provide health dept inspection report ( upload to permit ) Submit Backflow certification
---	--------------------------	---

**Comments:**