

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20213183  
Address: 2106 SW RUTHERFORD DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Patrick Schonfeldt	Failed	Wednesday, January 19, 2022

Corrective Action Required:

1	Misc	-secure all vertical DWV 2" or less at mid point -add floor receptacle required at 1st floor stair wall -Fireblock all tub and shower traps -seal all bottom plate penetration -great room -seal all top plate penetrations - great room, master bedroom -Install back door -Exterior wall bracing CS-PF design per plans at great room windows, see detail in plans/IRC R602.10.6.4, nail exterior sheathing -Nail exterior sheathing per plans
---	------	---

Comments: