

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204944
Address: 214 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Eric Sharp	Partial	Thursday, January 20, 2022

Informational:
1 Misc Driveway was framed up with aggregate in and compacted. Driveway was framed with wings at 39' had them adjust to 36'. 1/3/22 ES

Informational:
2 Misc Driveway was poured, still covered with blankets. Will reinspect after blanket removal. 1/20/22 ES

Comments: