

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20210744  
Address: 2155 NW KILLARNEY LN, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Robb Popp	Failed	Thursday, January 20, 2022

Corrective Action Required:

1	Misc	-Complete Final grade and sod -Splash blocks discharge 36" from foundation -check water meter and siding from grade at time of final grade and sod
---	------	--

TCO expiration 3/18/22

**Comments:**