

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20215818
Address: 56 NE SYCAMORE ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Michael Harkins	Failed	Thursday, January 20, 2022

Corrective Action Required:

1	Miscellaneous Correction	SEATS OF WATER CLOSETS PROVIDED FOR PUBLIC OR EMPLOYEE TOILET FACILITIES SHALL BE OF THE HINGED OPEN FRONT TYPE (2018 IPC 425.3) PROVIDE GFCI PROTECTION RECEPTACLES AT MOP SINK
---	--------------------------	---

Comments: