

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20212082
Address: 1100 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Michael Harkins	Failed	Thursday, January 20, 2022

Corrective Action Required:

1	Miscellaneous Correction	Provide permanent ladder for roof access Provide health dept inspection report (upload to permit) Submit Backflow certification Provide backflow devices at soda,water,coffee Pay not ready fees - ADDRESS ABOVE ITEMS TO OBTAIN TCO/ C of O - : OK TO STOCK AND TRAIN ONLY :
---	--------------------------	--

Comments: