

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20211583
Address: 1705 SW HIGHTOWN DR, LEES SUMMIT, MO 64082
Inspected On: Thursday, January 20, 2022
Inspected By: Patrick Schonfeldt
Expiration Date: 3/14/2022 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Temporary C of O	Thursday, January 20, 2022

Corrective Action Required:

1	Misc	-final driveway inspection required, contact development services to schedule -final grade and sod -splash blocks at downspouts and sump pump discharge -complete stone/siding at front of house -address numbers must contrast in color from background color -seal all penetrations in siding, seal along top of AC disconnect and meter can
---	------	---

****OK FOR TCO, TCO EXPIRES 3/14/22****

