

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210252
Address: 138 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Residential	Michael Harkins	Failed	Friday, January 21, 2022

Corrective Action Required:

1	Misc	- SUMBIT ENGINEERS SOIL REPORT & REPORT ON 8" LIFT COMPACTION ON AB-3 -
---	------	---

Comments: