

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220072
Address: 2021 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Friday, January 21, 2022

Corrective Action Required:

1	Miscellaneous Correction	Seal upward penetration rear bedroom furr out Provide boca plate dwv front bedroom closet Seal horizontal & vertical fire blocking throughout at furr out Seal upward penetrations bathroom Fire block soffit rec room west wall
---	--------------------------	--

Comments: